

Certificate of Compliance



This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

You have been awarded:

Intertek WH US + C Mark for Category B - Doors - Additional Edge-sealing System Required, Category A - Doors - No Additional Edge-sealing System Required

Standards: NFPA 252 (1995), UL 10(c) (1998), CAN4 S104 (1985), NFPA 252 (2008), UL 10(c) (2009), CAN / ULC S104 (2010), NFPA 252 (2012)

Certificate number: WHI15-15906303

Organization: Al Ghamdi Wood Industries Company Ltd.
P.O. Box 2880
Dammam Industrial Area 2
Dammam 31461
Kingdom of Saudi Arabia

Product: Halspan 45 Min Flush Fire Doors PP/NP

Spec ID: 32636

Fire Rating: 45 Min Neutral Pressure, 45 Min PP Category B Door, 45 Min PP Category A Door


Listing Information: See following page(s)

Certification body: Intertek Testing Services NA, Inc.

Initial registration: September 07, 2015

Date of expiry: December 31, 2024

Issue status: 8

Authorized By: 

Jean-Philippe Kayl, Director of Certification

Intertek Testing Services NA, Inc.
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA
Phone: 847-439-5667 Fax: 847-439-7320

www.intertek.com

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

LISTING INFORMATION

Category "A" Mineral Core Type, Swinging door for use in 45 minute positive pressure assemblies (also eligible for use in neutral pressure assemblies). For use in listed and labeled 16 or 18 gauge steel frames. For use in any "Category C - Standard" frame. These doors may also be installed in frames listed in "Category C - Proprietary" in accordance with the frame manufacturer's individual listing.

Category "B" Mineral Core Type, Swinging door for use in 45 minute positive pressure assemblies (also eligible for use in neutral pressure assemblies). For use in listed and labeled 16 or 18 gauge steel frames. For use in any "Category C - Standard" frame. These doors may also be installed in frames listed in "Category C - Proprietary" in accordance with the frame manufacturer's individual listing. A field-applied meeting edge seal system may be required.

MAXIMUM SIZES

Singles 4'-0 wide x 9'-0 high

Pairs (Standard and Double Egress) 8'-0 wide x 9'-0 high

PARAMETERS

1.
 1. Single swing, standard pairs and double egress
 2. Mortise or Cylindrical Latches with maximum 5" backset
 3. Mortised Exit Devices
 4. Concealed or Surface-Mounted Vertical Rod Fire Exit Devices (Thermal Pins Optional but NOT Required)
 5. Rim-Type Fire Exit Devices
 6. Deadbolts/Surface Bolts/Automatic Flush Bolts
 7. Surface-Mounted Closers
 8. Edge-Guards/Surface-Mounted Protection Plates
 9. Surface-Mounted or Mortised Door Bottoms
 10. Metal Edge or Astragal Optional
 11. Temperature Rise - 250°F at 30 minutes
 12. Listed and labeled lite kits in accordance with lite kit's listing.

*See manufacturer's installation instructions for additional information on Smoke and Draft Control, size restrictions and limitations.

TESTING STANDARDS

UBC-7-2-97/UL-10C (Positive Pressure)/NFPA 252/ CAN4 S104 (1985).

EVALUATED TO THE FOLLOWING...

This category includes doors evaluated with an edge-sealing system (Category G) field-applied to the labeled frame or door. The application of the edge-sealing system does not require any machining of the frame or door. Please refer to "Category G - Edge-Sealing System" for individual manufacturer's listings.

These assemblies are eligible for use in any "Category C - Standard" frame. These doors may also be installed in frames listed in "Category C - Proprietary" in the accordance with the frame manufacturer's individual listing.

All doors listed in Category B are eligible to bear the "S" (for Smoke & Draft Control assemblies) if a listed "Category H - Smoke & Draft Control Gasket" has been applied to the assembly. Please refer to Category H for individual gasket manufacturer's listings.

All doors in this category are identified by a label or marking bearing the wording, "Listed Fire Door", a time interval, a temperature rise rating, a serial number and the Warnock Hersey Certification Mark and "UBC-7-2-97/UL 10C/NFPA 252".